



High-Piled Combustible Storage Disclosure

The following information will be used to determine the requirements for fire protection as specified in the 2018 International Fire Code Ch. 32 and applicable referenced NFPA Standards.

BUILDING ADDRESS _____ PERMIT # _____

COMPANY NAME _____

CHECK HERE AND SIGN BELOW IF THIS FACILITY WILL NOT HAVE STORAGE OF HIGH-HAZARD COMMODITIES OVER 6 FT. HIGH TO TOP OF STORAGE OR OVER 12 FT. HIGH TO TOP OF STORAGE FOR ALL OTHER COMMODITIES.

LIST ALL COMMODITIES TO BE STORED WITHIN THE HIGH-PILED STORAGE AREA OVER 6 FT. HIGH FOR HIGH-HAZARD COMMODITIES AND OVER 12 FT. HIGH FOR ALL OTHER COMMODITIES.

COMMODITY	CLASS	STORAGE AREA (SQ FT)	STORAGE HEIGHT	STORAGE METHOD *	ENCAPSULATED (Y/N)	AISLE WIDTH

*Closely packed piles (CPP), pallets, racks, shelves, or mechanical stocking system (MSS).
 I certify that our combustible storage will be limited as indicated above.

SIGNED: _____ DATE: _____
 Business Owner or Representative

TITLE: _____

DEFINITIONS

- COMMODITY** – is a combination of products, packing materials, and containers.
- HIGH-PILED STORAGE AREA** –an area within a building that is designated, intended, proposed, or actually used for high-piled combustible storage, including operating aisles.
- HIGH-PILED COMBUSTIBLE STORAGE.** Storage of combustible materials in closely packed piles or combustible materials on pallets, in racks, or on shelves where the top of storage is greater than 12 feet (3658 mm) in height. Where required by the fire code official, high-piled combustible storage also includes certain high-hazard commodities, such as rubber tires, Group A plastics, flammable liquids, idle pallets, and similar commodities, where the top of storage is greater than 6 feet (1829 mm) in height.
- ENCAPSULATED** – is a method of packaging consisting of a plastic sheet completely enclosing the sides and top of a pallet load. The term encapsulated does not apply to banding or individual plastic-enclosed items inside a large non-plastic enclosed container.
- EXTRA HIGH-RACK COMBUSTIBLE STORAGE** – is storage on racks of Class I, II, III, or IV commodities that exceed 40 feet (121 920mm) in height and storage on racks of high-hazard commodities that exceed 30 feet (9144mm) in height.
- CLASS** – See 2018 International Fire Code Ch. 32, Section 3203 for examples of Class I, II, III, IV, and High Hazard Commodities, and Group A, B, and C Plastics.